



Product Service

CERTIFICATE

No. Z1A 16 05 70428 021

Holder of Certificate:

Factory(ies): 70428

Certification Mark:



Product: **Adaptors**
 Model(s): **FR101, FR102, FR103, FR104**

Parameters: Rated voltage: 250V~
 Rated frequency: 50Hz
 Rated current: 16A
 Protection class: I
 Protection degree: IP 20
 Remark:
 SPD Type 3, Uc: 250V~
 Uoc=6KV (for L-N, L/N-PE)
 Up=2KV (for L-N, L/N-PE)

Tested according to: DIN VDE 0620-1:2013
 DIN VDE 0620-2-1:2013
 EN 61643-11:2012
 EN 41003:2008
 AfPS GS 2014:01 PAK

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

Test report no.: 704101610404-00
 Valid until: 2021-05-16

Date, 2016-05-19
 Page 1 of 1

(Yi Zhu)

