

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 50431875

Blatt *Sheet*  
0001

Ihr Zeichen *Client Reference*  
Z.S.C.

Unser Zeichen *Our Reference*  
01-Wuchale-50157630 002

Ausstellungsdatum *Date of Issue*  
20.03.2019  
(day/mo/yr)

Genehmigungsinhaber *License Holder*  
ProJoy Electric Co., Ltd.  
XinTang Industrial Zone,  
North-city Street,  
PingJiang District,  
Suzhou 215000  
P. R. China

Fertigungsstätte *Manufacturing Plant*  
030-0000481189

## Prüfzeichen *Test Mark*



Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1419067189

Geprüft nach *Tested acc. to*  
EN 50539-11:2013+A1

Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)*

Lizenzentgelte - Einheit  
*License Fee - Unit*

Surge Protector (SPD)

Type Designation: PESP-1000  
Trade Mark : PROJOY  
Ucpv : DC 1000 V  
In : 20 kA  
Imax : 40 kA  
Up : 3500 V(+ to PE, - to PE, + to -)  
Type of SPD : Type 2  
Number of ports : One port  
Iscpv : 500 A  
IP code : IP20

6

6



Zertifizierungsstelle

Zhao Xinhua

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com  
Fax: +49 221 806-3935 http://www.tuv.com/safety